ABE Laboratories, LLC

Certificate of Water Analysis

7596-B Beth-Bath Pike
Bath, PA 18014
(610) 837-7721 ABE-LABS.com
DEP Laboratory ID: 48-00108

Sample Number: 26-14605
Report Date: 08/03/26
Version: Initial

Client Business: Wild Blue Group

Client Name: Thom Schiavone

Sample Address:
184 Lakewood Drive
Milford, PA 18337

Source: Well

Sample Location: Kitchen

Date Collected: 07/22/26

Time Collected: 1330

Sampled By: T. Schiavone

Test	Result	Units	Method	MCL	P/F	QL	Prep Date /Time	Analysis Date
Nitrate*	**<2.5**	mg/L	Orion ATI 601	10	**Pass**	2.5	07/24/26 0925	07/24/26
Nitrite*	**<0.1**	mg/L	SM 4500-NO2-B	1	**Pass**	0.1	07/24/26 0925	07/24/26
Total Nitrate/Nitrite	**<2.5**	mg/L		10	**Pass**			07/24/26
pH*	**7.3**		SM 4500-H+ B	6.5-8.5	**Pass**	4.0-10.0		07/23/26
Total Dissolved Solids	**108**	mg/L	SM 2540 C	500	**Pass**	100		07/27/26
Hardness	**5.8**	gpg	Manver 2 Buret			0.6		07/27/26
Iron	**0.02**	mg/L	1,10 Phenanthroline	0.3	**Pass**	0.02		07/27/26
Manganese	**<0.01**	mg/L	PAN	0.05	**Pass**	0.01		07/27/26

Results are reported on an “as received” basis.
This report may not be reproduced except in full without the written approval of ABE Laboratories.

Approved by: Gregory E Ness **Laboratory Supervisor** Approval Date: 08/03/26

Gregory E Ness

Report Notes:
* Tests are covered by ABE Laboratory’s scope of accreditation.
^ Tests are subcontracted to a DEP certified laboratory. See attached report(s).
MCL: Maximum Contaminant Level based on EPA standards.
QL: Quantitation Limit is the lowest concentration measurable for a specific test.

END OF REPORT

Certificate of Analysis

M.J. Reider Associates, Inc.
ENVIRONMENTAL TESTING LABORATORY
PA DEP #06-00003

Laboratory No.: 2634750
Reported: 07/31/26
Lab Contact: Paulina Laudan Webb

Attention: Reports
Reported To: ABE Lab
7596B Beth-Bath Pike
Bath, PA 18014

Project: Homeowner Metals (NON-DEP)

Lab ID: 2634750-03 **Collected By:** Client **Sampled:** 07/22/26 13:30 **Received:** 07/24/26 13:40
Sample Desc: 26-14605 184 Lakewood Drive **Sample Type:** Grab
Notes:

	Result	Unit	Rep. Limit	Analysis Method	Analyzed	Notes	Analyst	EPA MCL Min/Max		Pass/ Fail
Total Metals										
Lead	<0.001	mg/L	0.001	EPA 200.8 Rev 5.4	07/29/26		MPB	N/A	0.015	*

Notes and Definitions

Pass Result complies with PADEP maximum contaminant levels for safe drinking water.

Fail Result does not comply with PADEP maximum contaminant levels for safe drininking water.

* Maximum contaminant limits of 0.005 mg/l for Lead and 1.0 mg/l for Copper apply to bottled/purchased water. Averaged maximum contaminant limits of 0.015 mg/l for Lead and 1.3 mg/l for Copper apply to public water supplies.

This certificate shall not be reproduced except in full without the written approval of M.J. Reider Associates, Inc.
NELAP accredited by PA. (PADEP #06-00003) Visit our website to view our current
NELAC accreditations for various drinking water, wastewater and solid & chemical materials analytes.
Additional accreditations by MD (261)

ABE Laboratories, LLC

Certificate of Water Analysis

7596-B Beth-Bath Pike
Bath, PA 18014
(610) 837-7721 ABE-LABS.com
DEP Laboratory ID: 48-00108

Sample Number: 26-14605
Report Date: 08/03/26
Version: Initial

Client Business: Wild Blue Group

Client Name: Thom Schiavone

Sample Address:
184 Lakewood Drive
Milford, PA 18337

Source: Well

Sample Location: Kitchen

Date Collected: 07/22/26

Time Collected: 1330

Sampled By: T. Schiavone

Test	Result	Units	Method	MCL	P/F	QL	Prep Date /Time	Analysis Date
Total Coliform/100mL*	**Absent**		SM 9223	0	**Pass**	1	07/23/26 1519	07/24/26
E. coli/100mL*	**Absent**		SM 9223	0	**Pass**	1	07/23/26 1519	07/24/26
Nitrate*	**<2.5**	mg/L	Orion ATI 601	10	**Pass**	2.5	07/24/26 0925	07/24/26
Nitrite*	**<0.1**	mg/L	SM 4500-NO2-B	1	**Pass**	0.1	07/24/26 0925	
Total Nitrate/Nitrite	**<2.5**	mg/L		10	**Pass**			07/24/26
Outsourced Tests^	First Draw Lead				**Pass, Report Attached**			
pH*	**7.3**		SM 4500-H+ B	6.5-8.5	**Pass**	4.0-10.0		07/23/26
Iron	**0.02**	mg/L	1,10 Phenanthroline	0.3	**Pass**	0.02		07/27/26

Results are reported on an “as received” basis.
This report may not be reproduced except in full without the written approval of ABE Laboratories.

Approved by: Gregory E Ness **Laboratory Supervisor** Approval Date: 08/03/26

Gregory E Ness

Report Notes:
* Tests are covered by ABE Laboratory’s scope of accreditation.
^ Tests are subcontracted to a DEP certified laboratory. See attached report(s).
MCL: Maximum Contaminant Level based on EPA standards.
QL: Quantitation Limit is the lowest concentration measurable for a specific test.

END OF REPORT